



Input Report

Workspace: Eurogalva_ACL_Jan2024

3600 s

Study

Eurogalva_ACL_Jan2024

Tab	Group	Field	Value	Units
Context of calculations	Selection of context	Weathers to use for this study	Weather folder	
		Parameters to use for this study	3600s	
		Obstructions to use for this study		
Material	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Concrete, no bund	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)		
Dispersion	Distances of interest	Distances of interest		m

04a Incendio armazém de pintura líquida

Atmospheric storage tank

Eurogalva_ACL_Jan2024\3600 s

Tab	Group	Field	Value	Units
Material	Material	Material	CARBON MONOXIDE	
		Specify volume inventory?	No	
		Mass inventory	18	kg
		Volume inventory	0,0610727	m3
		Material to track	CARBON MONOXIDE	
	Phase	Specified condition	Temperature and atmospheric pressure	
		Temperature	15,5	degC
		Pressure (gauge)		bar
		Fluid state	Liquid	
		Liquid mole fraction	1	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length		m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m
	Frequencies of valves	Frequency of excess flow valves	0	/m

		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	0,0610727	m3
		Tank vapour volume	0	m3
		Tank liquid volume	0,0610727	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
Dispersion	Dispersion scope	Concentration of interest		ppm
		Averaging time for concentration of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
	Distances of interest	Distances of interest		m
	Averaging time for reports	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Armazém pintura líquida	
	Building definition	Release building	Buildings\Armazém Pintura\Building	

		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)		
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	4	
		Dose levels	130000; 1,3E+06; 1,3E+07; 1,3E+08	
		Probit levels	2; 3; 4; 10	
		Lethality levels	0,001; 0,01; 0,1; 0,99	fraction
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined		

		source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Jet fire	Jet fire method	Jet fire method	Cone model	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	-5,52865	m
		North	-5,8006	m

User defined source

User defined source

Eurogalva_ACL_Jan2024\3600 s\04a_Incendio armazém de pintura líquida

Tab	Group	Field	Value	Units
Scenario	Release scenario	Release scenario	Leak	
		The number of release observers	2	
	Release observers	Release time	0; 3600	s
		Release phase	Vapour; Vapour	
		Mass flow	0,005; 0,005	kg/s
		Final velocity	0,01; 0,01	m/s
		Final temperature	600; 600	degC
		Liquid fraction	0; 0	fraction
		Droplet diameter	0; 0	um
		Pool radius	0; 0	m
		Pre-dilution air rate	1; 1	kg/s
		Downstream calculation status	No errors detected	
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
	Fireball emissive power	Use vessel burst pressure	No	
		Vessel burst pressure - gauge		bar
	Jet fire Miller model hole size	Orifice diameter	0	mm
Material	Material	Material characteristics	Toxic and flammable	
		Material to track	CARBON MONOXIDE	
		Type of risk effects to model	Toxic and flammable	
Dispersion	Dispersion scope	Concentration of interest		ppm
		Averaging time for concentration of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
	Distances of interest	Distances of interest		m
	Averaging time for reports	ERPG [1 hr]	No	

		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Armazém pintura líquida	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)		
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	4	
		Dose levels	130000; 1,3E+06; 1,3E+07; 1,3E+08	
		Probit levels	2; 3; 4; 10	
		Lethality levels	0,001; 0,01; 0,1; 0,99	fraction
Explosion parameters	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	

		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Jet fire method	Cone model	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	

		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s