

Input Report

Workspace: CapWatt_Mangualde_HyMeOH

120s

Study

CapWatt_Mangualde_HyMeOH

Tab	Group	Field	Value
Context of calculations	Selection of context	Weathers to use for this study	Weather folder
		Parameters to use for this study	120s
Material	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land
		Type of pool substrate and bunds	Concrete, no bund
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected
		Building type (downwind building type)	Buildings\Building type

8_Rotura linha de saída de gás de síntese do Gaseificador

Pressure vessel

CapWatt_Mangualde_HyMeOH\120s

Tab	Group	Field	Value	Units
Material	Material	Material	GÁS SÍNTESE	
		Specify volume inventory?	No	
		Mass inventory	1108,8	kg
		Volume inventory	3388,54	m3
		Material to track	GÁS SÍNTESE	
	Phase	Specified condition	Pressure/temperature	
		Temperature	880	degC
		Pressure (gauge)	1,4	bar
		Fluid state	Vapour	
		Liquid mole fraction	0	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	20	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	3388,54	m3
		Tank vapour volume	3388,54	m3
		Tank liquid volume	0	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Área de Gaseificação	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	None	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	

		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

8_Rotura linha de saída de gás de síntese do Gaseificador

Short pipe

CapWatt_Mangualde_HyMeOH\120s\8_Rotura linha de saída de gás de síntese do Gaseificador

Tab	Group	Field	Value	Units
Scenario	Scenario	Scenario type	Line rupture	
	Pipe dimensions	Pipe internal diameter	1800	mm
		Pipe length	20	m
	Hole	Orifice diameter		mm
	Release location	Elevation	0,1	m
		Tank head	0	m
	Flow control and isolation	Flow controller	Control valve	
		Input option	Fixed flow rate	
		Fixed flow rate	10,44	kg/s
		Pump head		m
		Active isolation valve		
		Valve closing time		s
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Toxic and flammable	
		Material to track	GÁS SÍNTESE	
	Phase	Phase to be released	Vapour	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m
	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return	0	/m

Audit Number: 11245

Date: 10/10/2025 Time: 11:19

Page 7 of 289

		valves		
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Área de Gaseificação	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction

	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
		Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
		Radiation levels	Number of input radiation levels	5
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
		Calculation method	Fireball model	Martinsen time varying

		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

9_Fuga 10% do diâmetro da linha de saída de gás de síntese do Gaseificador

Pressure vessel

CapWatt_Mangualde_HyMeOH\120s

Tab	Group	Field	Value	Units
Material	Material	Material	GÁS SÍNTESE	
		Specify volume inventory?	No	
		Mass inventory	1108,8	kg
		Volume inventory	3388,54	m3
		Material to track	GÁS SÍNTESE	
	Phase	Specified condition	Pressure/temperature	
		Temperature	880	degC
		Pressure (gauge)	1,4	bar
		Fluid state	Vapour	
		Liquid mole fraction	0	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	20	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	3388,54	m3
		Tank vapour volume	3388,54	m3
		Tank liquid volume	0	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Área de Gaseificação	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	

		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

9_Fuga 10% do diâmetro da linha de saída de gás de síntese do Gaseificador

Leak

CapWatt_Mangualde_HyMeOH\120s\9_Fuga 10% do diâmetro da linha de saída de gás de síntese do Gaseificador

Tab	Group	Field	Value	Units
Scenario	Hole	Orifice diameter	50	mm
		Use specified discharge coefficient?	Yes	
		Discharge coefficient	0,62	fraction
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Toxic and flammable	
		Material to track	GÁS SÍNTESE	
	Phase	Phase to be released	Vapour	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - continuous	Do not force correlation	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	

Audit Number: 11245

Date: 10/10/2025 Time: 11:19

Page 17 of 289

		Type of pool substrate and bunds	Área de Gaseificação	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	

		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	

		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

10_Rotura linha de saída de gás de síntese do Scrubber

Pressure vessel

CapWatt_Mangualde_HyMeOH\120s

Tab	Group	Field	Value	Units
Material	Material	Material	GÁS SÍNTESE	
		Specify volume inventory?	No	
		Mass inventory	1108,8	kg
		Volume inventory	1571,41	m3
		Material to track	GÁS SÍNTESE	
	Phase	Specified condition	Pressure/temperature	
		Temperature	40	degC
		Pressure (gauge)	0,4	bar
		Fluid state	Vapour	
		Liquid mole fraction	0	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	85	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	1571,41	m3
		Tank vapour volume	1571,41	m3
		Tank liquid volume	0	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack de Gás de Síntese para U-300	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	

		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

10_Rotura linha de saída de gás de síntese do Scrubber

Short pipe

CapWatt_Mangualde_HyMeOH\120s\10_Rotura linha de saída de gás de síntese do Scrubber

Tab	Group	Field	Value	Units
Scenario	Scenario	Scenario type	Line rupture	
	Pipe dimensions	Pipe internal diameter	900	mm
		Pipe length	85	m
	Hole	Orifice diameter		mm
	Release location	Elevation	0,1	m
		Tank head	0	m
	Flow control and isolation	Flow controller	None	
		Input option	Not applicable	
		Fixed flow rate	9,24	kg/s
		Pump head		m
		Active isolation valve		
		Valve closing time		s
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Toxic and flammable	
		Material to track	GÁS SÍNTESE	
	Phase	Phase to be released	Vapour	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m
	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return	0	/m

		valves		
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack de Gás de Síntese para U-300	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction

Explosion parameters	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
	Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	

		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

11_Fuga 10% do diâmetro da linha de saída de gás de síntese do Scrubber

Pressure vessel

CapWatt_Mangualde_HyMeOH\120s

Tab	Group	Field	Value	Units
Material	Material	Material	GÁS SÍNTESE	
		Specify volume inventory?	No	
		Mass inventory	1108,8	kg
		Volume inventory	1571,41	m3
		Material to track	GÁS SÍNTESE	
	Phase	Specified condition	Pressure/temperature	
		Temperature	40	degC
		Pressure (gauge)	0,4	bar
		Fluid state	Vapour	
		Liquid mole fraction	0	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	85	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	1571,41	m3
		Tank vapour volume	1571,41	m3
		Tank liquid volume	0	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack de Gás de Síntese para U-300	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	

		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

11_Fuga 10% do diâmetro da linha de saída de gás de síntese do Scrubber

Leak

CapWatt_Mangualde_HyMeOH\120s\11_Fuga 10% do diâmetro da linha de saída de gás de síntese do Scrubber

Tab	Group	Field	Value	Units
Scenario	Hole	Orifice diameter	50	mm
		Use specified discharge coefficient?	Yes	
		Discharge coefficient	0,62	fraction
		Elevation	0,1	m
	Release location	Tank head	0	m
		Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Toxic and flammable	
		Material to track	GÁS SÍNTESE	
	Phase	Phase to be released	Vapour	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
		Droplet break-up mechanism	Do not force correlation	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
		Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No
			IDLH [30 mins]	No
			STEL [15 mins]	No
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	

Audit Number: 11245

Date: 10/10/2025 Time: 11:19

Page 36 of 289

		Type of pool substrate and bunds	Piperack de Gás de Síntese para U-300	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	

		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	

		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

12_Rotura linha de saída de gás de síntese do compressor de MP

Pressure vessel

CapWatt_Mangualde_HyMeOH\120s

Tab	Group	Field	Value	Units
Material	Material	Material	GÁS SÍNTESE	
		Specify volume inventory?	No	
		Mass inventory	1057,1	kg
		Volume inventory	65,2862	m3
		Material to track	GÁS SÍNTESE	
	Phase	Specified condition	Pressure/temperature	
		Temperature	50	degC
		Pressure (gauge)	33	bar
		Fluid state	Vapour	
		Liquid mole fraction	0	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	100	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	65,2862	m3
		Tank vapour volume	65,2862	m3
		Tank liquid volume	0	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack de Gás de Síntese para a unidade de U-320	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	

		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

12_Rotura linha de saída de gás de síntese do compressor de MP

Short pipe

CapWatt_Mangualde_HyMeOH\120s\12_Rotura linha de saída de gás de síntese do compressor de MP

Tab	Group	Field	Value	Units
Scenario	Scenario	Scenario type	Line rupture	
	Pipe dimensions	Pipe internal diameter	152,4	mm
		Pipe length	100	m
	Hole	Orifice diameter		mm
	Release location	Elevation	0,1	m
		Tank head	0	m
	Flow control and isolation	Flow controller	None	
		Input option	Not applicable	
		Fixed flow rate	8,8	kg/s
		Pump head		m
		Active isolation valve		
		Valve closing time		s
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Toxic and flammable	
		Material to track	GÁS SÍNTESE	
	Phase	Phase to be released	Vapour	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m
	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return	0	/m

		valves		
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack de Gás de Síntese para a unidade de U-320	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction

Explosion parameters	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
	Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	

		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

13_Fuga 10% do diâmetro da linha de saída de gás de síntese do compressor de MP

Pressure vessel

CapWatt_Mangualde_HyMeOH\120s

Tab	Group	Field	Value	Units
Material	Material	Material	GÁS SÍNTESE	
		Specify volume inventory?	No	
		Mass inventory	1057,1	kg
		Volume inventory	65,2862	m3
		Material to track	GÁS SÍNTESE	
	Phase	Specified condition	Pressure/temperature	
		Temperature	50	degC
		Pressure (gauge)	33	bar
		Fluid state	Vapour	
		Liquid mole fraction	0	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	100	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	65,2862	m3
		Tank vapour volume	65,2862	m3
		Tank liquid volume	0	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack de Gás de Síntese para a unidade de U-320	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	

		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

13_Fuga 10% do diâmetro da linha de saída de gás de síntese do compressor de MP

Leak

CapWatt_Mangualde_HyMeOH\120s\13_Fuga 10% do diâmetro da linha de saída de gás de síntese do compressor de MP

Tab	Group	Field	Value	Units
Scenario	Hole	Orifice diameter	15,24	mm
		Use specified discharge coefficient?	Yes	
	Release location	Discharge coefficient	0,62	fraction
		Elevation	0,1	m
Material	Direction	Tank head	0	m
		Outdoor release direction	Horizontal	
	Material	Outdoor release angle	0	deg
		Material characteristics	Toxic and flammable	
Discharge parameters	Phase	Material to track	GÁS SÍNTESE	
		Phase to be released	Vapour	
	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
Dispersion	Droplet break-up mechanism	Droplet break-up mechanism - continuous	Do not force correlation	
		Concentrations of interest		ppm
	User-defined dispersion scope (N.B Based on the material to track)	Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
Bund, building and	Terrain and bund	STEL [15 mins]	No	
		Type of terrain for	Land	

terrain	definition	dispersion		
		Type of pool substrate and bunds	Piperack de Gás de Síntese para a unidade de U-320	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction

Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	

		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

14_Rotura linha de saída de gás de síntese purificado para a unidade de Síntese de Metanol

Pressure vessel

CapWatt_Mangualde_HyMeOH\120s

Tab	Group	Field	Value	Units
Material	Material	Material	GÁS SÍNTESE PURIFICADO	
		Specify volume inventory?	No	
		Mass inventory	378,3	kg
		Volume inventory	36,4459	m3
		Material to track	GÁS SÍNTESE PURIFICADO	
	Phase	Specified condition	Pressure/temperature	
		Temperature	50	degC
		Pressure (gauge)	33	bar
		Fluid state	Vapour	
		Liquid mole fraction	0	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	200	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	36,4459	m3
		Tank vapour volume	36,4459	m3
		Tank liquid volume	0	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack de Gás de Síntese Purificado para a unidade de U-410	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	

		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m ³
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m ²
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

14_Rotura linha de saída de gás de síntese purificado para a unidade de Síntese de Metanol

Short pipe

CapWatt_Mangualde_HyMeOH\120s\14_Rotura linha de saída de gás de síntese purificado para a unidade de Síntese de Metanol

Tab	Group	Field	Value	Units
Scenario	Scenario	Scenario type	Line rupture	
	Pipe dimensions	Pipe internal diameter	203,2	mm
		Pipe length	200	m
	Hole	Orifice diameter		mm
	Release location	Elevation	0,1	m
		Tank head	0	m
	Flow control and isolation	Flow controller	None	
		Input option	Not applicable	
		Fixed flow rate	3,2	kg/s
		Pump head		m
		Active isolation valve		
		Valve closing time		s
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Toxic and flammable	
		Material to track	GÁS SÍNTESE PURIFICADO	
	Phase	Phase to be released	Vapour	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m
	Frequencies of valves	Frequency of excess flow valves	0	/m

		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack de Gás de Síntese Purificado para a unidade de U-410	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction

		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum	20	s

		exposure duration		
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum	20	s

		exposure duration		
--	--	-------------------	--	--

15_Fuga 10% do diâmetro da linha de saída de gás de síntese purificado para a unidade de Síntese de Metanol

Pressure vessel

CapWatt_Mangualde_HyMeOH\120s

Tab	Group	Field	Value	Units
Material	Material	Material	GÁS SÍNTESE PURIFICADO	
		Specify volume inventory?	No	
		Mass inventory	378,3	kg
		Volume inventory	36,4459	m3
		Material to track	GÁS SÍNTESE PURIFICADO	
	Phase	Specified condition	Pressure/temperature	
		Temperature	50	degC
		Pressure (gauge)	33	bar
		Fluid state	Vapour	
		Liquid mole fraction	0	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	200	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	36,4459	m3
		Tank vapour volume	36,4459	m3
		Tank liquid volume	0	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack de Gás de Síntese Purificado para a unidade de U-410	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	

		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

15_Fuga 10% do diâmetro da linha de saída de gás de síntese purificado para a unidade de Síntese de Metanol Leak

CapWatt_Mangualde_HyMeOH\120s\15_Fuga 10% do diâmetro da linha de saída de gás de síntese purificado para a unidade de Síntese de Metanol

Tab	Group	Field	Value	Units
Scenario	Hole	Orifice diameter	20,32	mm
		Use specified discharge coefficient?	Yes	
		Discharge coefficient	0,62	fraction
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Toxic and flammable	
		Material to track	GÁS SÍNTese PURIFICADO	
	Phase	Phase to be released	Vapour	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - continuous	Do not force correlation	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and	Terrain and bund	Type of terrain for	Land	

terrain	definition	dispersion		
		Type of pool substrate and bunds	Piperack de Gás de Síntese Purificado para a unidade de U-410	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of		fraction

		confined source		
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction

Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
	Parameters	Lethality levels	0,01; 0,1; 0,99	fraction
		Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

16_Rotura linha de saída do compressor de gás síntese 41-K-001 para a unidade de Síntese de Metanol

Pressure vessel

CapWatt_Mangualde_HyMeOH\120s

Tab	Group	Field	Value	Units
Material	Material	Material	GÁS SÍNTESE	
		Specify volume inventory?	No	
		Mass inventory	1394,5	kg
		Volume inventory	45,7516	m3
		Material to track	GÁS SÍNTESE	
	Phase	Specified condition	Pressure/temperature	
		Temperature	92	degC
		Pressure (gauge)	73	bar
		Fluid state	Vapour	
		Liquid mole fraction	0	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	35	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	45,7516	m3
		Tank vapour volume	45,7516	m3
		Tank liquid volume	0	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Área de Compressão de Gás Síntese	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	

		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

16_Rotura linha de saída do compressor de gás síntese 41-K-001 para a unidade de Síntese de Metanol

Short pipe

CapWatt_Mangualde_HyMeOH\120s\16_Rotura linha de saída do compressor de gás síntese 41-K-001 para a unidade de Síntese de Metanol

Tab	Group	Field	Value	Units
Scenario	Scenario	Scenario type	Line rupture	
	Pipe dimensions	Pipe internal diameter	152,4	mm
		Pipe length	35	m
	Hole	Orifice diameter		mm
	Release location	Elevation	0,1	m
		Tank head	0	m
	Flow control and isolation	Flow controller	None	
		Input option	Not applicable	
		Fixed flow rate	12	kg/s
		Pump head		m
		Active isolation valve		
		Valve closing time		s
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Toxic and flammable	
		Material to track	GÁS SÍNTESE	
	Phase	Phase to be released	Vapour	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m
	Frequencies of valves	Frequency of excess flow valves	0	/m

		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Área de Compressão de Gás Síntese	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for	0	fraction

exposure time calculations				
Explosion parameters	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
	Explosion method	Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
		Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
	Multi-Energy	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s

	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

17_Fuga 10% do diâmetro da linha de saída do compressor de gás síntese 41-K-001 para a unidade de Síntese de Metanol

Pressure vessel

CapWatt_Mangualde_HyMeOH\120s

Tab	Group	Field	Value	Units
Material	Material	Material	GÁS SÍNTESE	
		Specify volume inventory?	No	
		Mass inventory	1394,5	kg
		Volume inventory	45,7516	m3
		Material to track	GÁS SÍNTESE	
	Phase	Specified condition	Pressure/temperature	
		Temperature	92	degC
		Pressure (gauge)	73	bar
		Fluid state	Vapour	
		Liquid mole fraction	0	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	35	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in	0	/m

		pipe		
	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	45,7516	m3
		Tank vapour volume	45,7516	m3
		Tank liquid volume	0	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	

		User defined averaging time	s	
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Área de Compressão de Gás Síntese	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition	No ignition location	

		location		
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	

		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

17_Fuga 10% do diâmetro da linha de saída do compressor de gás síntese 41-K-001 para a unidade de Síntese de Metanol

Leak

CapWatt_Mangualde_HyMeOH\120s\17_Fuga 10% do diâmetro da linha de saída do compressor de gás síntese 41-K-001 para a unidade de Síntese de Metanol

Tab	Group	Field	Value	Units
Scenario	Hole	Orifice diameter	15,24	mm
		Use specified discharge coefficient?	Yes	
		Discharge coefficient	0,62	fraction
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Toxic and flammable	
		Material to track	GÁS SÍNSESE	
	Phase	Phase to be released	Vapour	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - continuous	Do not force correlation	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	

Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Área de Compressão de Gás Síntese	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of		fraction

		confined source		
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction

Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

18_Rotura linha de alimentação de gás de síntese de reciclo para a compressão de gás

Pressure vessel

CapWatt_Mangualde_HyMeOH\120s

Tab	Group	Field	Value	Units
Material	Material	Material	GÁS SÍNTESE	
		Specify volume inventory?	No	
		Mass inventory	392,767	kg
		Volume inventory	24,979	m3
		Material to track	GÁS SÍNTESE	
	Phase	Specified condition	Pressure/temperature	
		Temperature	50	degC
		Pressure (gauge)	32	bar
		Fluid state	Vapour	
		Liquid mole fraction	0	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	170	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	24,979	m3
		Tank vapour volume	24,979	m3
		Tank liquid volume	0	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Área de Compressão de Gás Síntese	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	

		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

18_Rotura linha de alimentação de gás de síntese de reciclo para a compressão de gás

Short pipe

CapWatt_Mangualde_HyMeOH\120s\18_Rotura linha de alimentação de gás de síntese de reciclo para a compressão de gás

Tab	Group	Field	Value	Units
Scenario	Scenario	Scenario type	Line rupture	
	Pipe dimensions	Pipe internal diameter	203,2	mm
		Pipe length	170	m
	Hole	Orifice diameter		mm
	Release location	Elevation	0,1	m
		Tank head	0	m
	Flow control and isolation	Flow controller	None	
		Input option	Not applicable	
		Fixed flow rate		kg/s
		Pump head		m
		Active isolation valve		
		Valve closing time		s
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Toxic and flammable	
		Material to track	GÁS SÍNTESE	
	Phase	Phase to be released	Vapour	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m
	Frequencies of valves	Frequency of excess flow valves	0	/m

		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Área de Compressão de Gás Síntese	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for	0	fraction

exposure time calculations				
Explosion parameters	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
	Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s

	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

19_Fuga 10% do diâmetro da linha de alimentação de gás de síntese de reciclo para a compressão de gás

Pressure vessel

CapWatt_Mangualde_HyMeOH\120s

Tab	Group	Field	Value	Units
Material	Material	Material	GÁS SÍNTESE	
		Specify volume inventory?	No	
		Mass inventory	392,767	kg
		Volume inventory	24,979	m3
		Material to track	GÁS SÍNTESE	
	Phase	Specified condition	Pressure/temperature	
		Temperature	50	degC
		Pressure (gauge)	32	bar
		Fluid state	Vapour	
		Liquid mole fraction	0	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	170	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	24,979	m3
		Tank vapour volume	24,979	m3
		Tank liquid volume	0	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Área de Compressão de Gás Síntese	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	

		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

19_Fuga 10% do diâmetro da linha de alimentação de gás de síntese de reciclo para a compressão de gás

Leak

CapWatt_Mangualde_HyMeOH\120s\19_Fuga 10% do diâmetro da linha de alimentação de gás de síntese de reciclo para a compressão de gás

Tab	Group	Field	Value	Units
Scenario	Hole	Orifice diameter	20,32	mm
		Use specified discharge coefficient?	Yes	
		Discharge coefficient	0,62	fraction
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Toxic and flammable	
		Material to track	GÁS SÍNTESE	
	Phase	Phase to be released	Vapour	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - continuous	Do not force correlation	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and	Terrain and bund	Type of terrain for	Land	

terrain	definition	dispersion		
		Type of pool substrate and bunds	Área de Compressão de Gás Síntese	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction

Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	

		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

22_Rotura catastrófica de reator 42-R-001

Pressure vessel

CapWatt_Mangualde_HyMeOH\120s

Tab	Group	Field	Value	Units
Material	Material	Material	METANOL BRUTO	
		Specify volume inventory?	No	
		Mass inventory	1905	kg
		Volume inventory	126,8	m3
		Material to track	METANOL BRUTO	
	Phase	Specified condition	Pressure/temperature	
		Temperature	234	degC
		Pressure (gauge)	61,4	bar
		Fluid state	Vapour	
		Liquid mole fraction	0	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length		m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	126,8	m3
		Tank vapour volume	126,8	m3
		Tank liquid volume	0	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Concrete, no bund	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: Uniform confined	
	Ignition	Supply late ignition location	No ignition location	

		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	

Surface emissive power		Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

22_Rotura catastrófica de reator 42-R-001

Catastrophic rupture

CapWatt_Mangualde_HyMeOH\120s\22_Rotura catastrófica de reator 42-R-001

Tab	Group	Field	Value	Units
Scenario	Release location	Elevation	0,1	m
		Tank head	0	m
	Fireball emissive power	Use vessel burst pressure	No	
		Vessel burst pressure - gauge		bar
Material	Material	Material characteristics	Toxic and flammable	
		Material to track	METANOL BRUTO	
Discharge parameters	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Concrete, no bund	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal	Use a fixed averaging time	

		to exposure time		
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method	Explosion method	Multi-Energy: Uniform confined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation	5	

levels				
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

23_Fuga de 100mm de reator 42-R-001

Pressure vessel

CapWatt_Mangualde_HyMeOH\120s

Tab	Group	Field	Value	Units
Material	Material	Material	METANOL BRUTO	
		Specify volume inventory?	No	
		Mass inventory	1905,37	kg
		Volume inventory	126,824	m3
		Material to track	METANOL BRUTO	
	Phase	Specified condition	Pressure/temperature	
		Temperature	234	degC
		Pressure (gauge)	61,4	bar
		Fluid state	Vapour	
		Liquid mole fraction	0	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length		m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	126,824	m3
		Tank vapour volume	126,824	m3
		Tank liquid volume	0	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Área de Síntese de Metanol	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	

		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

23_Fuga de 100mm de reator 42-R-001

Leak

CapWatt_Mangualde_HyMeOH\120s\23_Fuga de 100mm de reator 42-R-001

Tab	Group	Field	Value	Units
Scenario	Hole	Orifice diameter	100	mm
		Use specified discharge coefficient?	Yes	
		Discharge coefficient	0,62	fraction
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Toxic and flammable	
		Material to track	METANOL BRUTO	
	Phase	Phase to be released	Vapour	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - continuous	Do not force correlation	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	

Audit Number: 11245

Date: 10/10/2025 Time: 11:19

Page 129 of 289

		Type of pool substrate and bunds	Área de Síntese de Metanol	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	

		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	

		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

24_Fuga de 10mm de reator 42-R-001

Pressure vessel

CapWatt_Mangualde_HyMeOH\120s

Tab	Group	Field	Value	Units
Material	Material	Material	METANOL BRUTO	
		Specify volume inventory?	No	
		Mass inventory	1905,37	kg
		Volume inventory	126,824	m3
		Material to track	METANOL BRUTO	
	Phase	Specified condition	Pressure/temperature	
		Temperature	234	degC
		Pressure (gauge)	61,4	bar
		Fluid state	Vapour	
		Liquid mole fraction	0	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length		m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	126,824	m3
		Tank vapour volume	126,824	m3
		Tank liquid volume	0	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Área de Síntese de Metanol	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	

		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m ³
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m ²
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

24_Fuga de 10mm de reator 42-R-001

Leak

CapWatt_Mangualde_HyMeOH\120s\24_Fuga de 10mm de reator 42-R-001

Tab	Group	Field	Value	Units
Scenario	Hole	Orifice diameter	10	mm
		Use specified discharge coefficient?	Yes	
		Discharge coefficient	0,62	fraction
		Elevation	0,1	m
	Release location	Tank head	0	m
		Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Toxic and flammable	
		Material to track	METANOL BRUTO	
	Phase	Phase to be released	Vapour	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
		Droplet break-up mechanism	Do not force correlation	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
		Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No
			IDLH [30 mins]	No
			STEL [15 mins]	No
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	

Audit Number: 11245

Date: 10/10/2025 Time: 11:19

Page 138 of 289

		Type of pool substrate and bunds	Área de Síntese de Metanol	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	

		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	

		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

25_Rotura da linha de saída do Flash Drum 42-V-003 da síntese de metanol

Pressure vessel

CapWatt_Mangualde_HyMeOH\120s

Tab	Group	Field	Value	Units
Material	Material	Material	METANOL BRUTO	
		Specify volume inventory?	No	
		Mass inventory	379,233	kg
		Volume inventory	162,21	m3
		Material to track	METANOL BRUTO	
	Phase	Specified condition	Pressure/temperature	
		Temperature	48	degC
		Pressure (gauge)	5	bar
		Fluid state	Vapour	
		Liquid mole fraction	0	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	7	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	162,21	m3
		Tank vapour volume	162,21	m3
		Tank liquid volume	0	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Área de Síntese de Metanol	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	

		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

25_Rotura da linha de saída do Flash Drum 42-V-003 da síntese de metanol

Short pipe

CapWatt_Mangualde_HyMeOH\120s\25_Rotura da linha de saída do Flash Drum 42-V-003 da síntese de metanol

Tab	Group	Field	Value	Units
Scenario	Scenario	Scenario type	Line rupture	
	Pipe dimensions	Pipe internal diameter	76,2	mm
		Pipe length	7	m
	Hole	Orifice diameter		mm
	Release location	Elevation	0,1	m
		Tank head	0	m
	Flow control and isolation	Flow controller	None	
		Input option	Not applicable	
		Fixed flow rate	3	kg/s
		Pump head		m
		Active isolation valve		
		Valve closing time		s
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Toxic and flammable	
		Material to track	METANOL BRUTO	
	Phase	Phase to be released	Vapour	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m
	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return	0	/m

		valves		
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Área de Síntese de Metanol	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction

Explosion parameters	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
	Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	

		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

26_Fuga da linha de saída do Flash Drum 42-V-003 da síntese de metanol

Pressure vessel

CapWatt_Mangualde_HyMeOH\120s

Tab	Group	Field	Value	Units
Material	Material	Material	METANOL BRUTO	
		Specify volume inventory?	No	
		Mass inventory	379,233	kg
		Volume inventory	162,21	m3
		Material to track	METANOL BRUTO	
	Phase	Specified condition	Pressure/temperature	
		Temperature	48	degC
		Pressure (gauge)	5	bar
		Fluid state	Vapour	
		Liquid mole fraction	0	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	7	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	162,21	m3
		Tank vapour volume	162,21	m3
		Tank liquid volume	0	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Área de Síntese de Metanol	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	

		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

26_Fuga da linha de saída do Flash Drum 42-V-003 da síntese de metanol

Leak

CapWatt_Mangualde_HyMeOH\120s\26_Fuga da linha de saída do Flash Drum 42-V-003 da síntese de metanol

Tab	Group	Field	Value	Units
Scenario	Hole	Orifice diameter	7,62	mm
		Use specified discharge coefficient?	Yes	
		Discharge coefficient	0,62	fraction
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Toxic and flammable	
		Material to track	METANOL BRUTO	
	Phase	Phase to be released	Vapour	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - continuous	Do not force correlation	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	

Audit Number: 11245

Date: 10/10/2025 Time: 11:19

Page 157 of 289

		Type of pool substrate and bunds	Área de Síntese de Metanol	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	

		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	

		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

30_Rotura da Linha de topo da coluna de destilação 43-C-001

Pressure vessel

CapWatt_Mangualde_HyMeOH\120s

Tab	Group	Field	Value	Units
Material	Material	Material	METANOL BRUTO	
		Specify volume inventory?	No	
		Mass inventory	385,633	kg
		Volume inventory	675,114	m3
		Material to track	METANOL BRUTO	
	Phase	Specified condition	Pressure/temperature	
		Temperature	79	degC
		Pressure (gauge)	0,6	bar
		Fluid state	Vapour	
		Liquid mole fraction	0	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	5	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	675,114	m3
		Tank vapour volume	675,114	m3
		Tank liquid volume	0	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Área de Destilação/ Refinação de Metanol	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	

		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m ³
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m ²
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

30_Rotura da Linha de topo da coluna de destilação 43-C-001

Short pipe

CapWatt_Mangualde_HyMeOH\120s\30_Rotura da Linha de topo da coluna de destilação 43-C-001

Tab	Group	Field	Value	Units
Scenario	Scenario	Scenario type	Line rupture	
	Pipe dimensions	Pipe internal diameter	254	mm
		Pipe length	5	m
	Hole	Orifice diameter		mm
	Release location	Elevation	0,1	m
		Tank head	0	m
	Flow control and isolation	Flow controller	None	
		Input option	Not applicable	
		Fixed flow rate	3	kg/s
		Pump head		m
		Active isolation valve		
		Valve closing time		s
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Toxic and flammable	
		Material to track	METANOL BRUTO	
	Phase	Phase to be released	Vapour	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m
	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return	0	/m

Audit Number: 11245

Date: 10/10/2025 Time: 11:19

Page 166 of 289

		valves		
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Área de Destilação/ Refinação de Metanol	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction

	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
		Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
		Radiation levels	Number of input radiation levels	5
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
		Calculation method	Fireball model	Martinsen time varying

		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

31_Fuga da Linha de topo da coluna de destilação 43-C-001

Pressure vessel

CapWatt_Mangualde_HyMeOH\120s

Tab	Group	Field	Value	Units
Material	Material	Material	METANOL BRUTO	
		Specify volume inventory?	No	
		Mass inventory	385,633	kg
		Volume inventory	675,114	m3
		Material to track	METANOL BRUTO	
	Phase	Specified condition	Pressure/temperature	
		Temperature	79	degC
		Pressure (gauge)	0,6	bar
		Fluid state	Vapour	
		Liquid mole fraction	0	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	5	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	675,114	m3
		Tank vapour volume	675,114	m3
		Tank liquid volume	0	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Área de Destilação/ Refinação de Metanol	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	

		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

31_Fuga da Linha de topo da coluna de destilação 43-C-001

Leak

CapWatt_Mangualde_HyMeOH\120s\31_Fuga da Linha de topo da coluna de destilação 43-C-001

Tab	Group	Field	Value	Units
Scenario	Hole	Orifice diameter	25,4	mm
		Use specified discharge coefficient?	Yes	
		Discharge coefficient	0,62	fraction
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Toxic and flammable	
		Material to track	METANOL BRUTO	
	Phase	Phase to be released	Vapour	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - continuous	Do not force correlation	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	

Audit Number: 11245

Date: 10/10/2025 Time: 11:19

Page 176 of 289

		Type of pool substrate and bunds	Área de Destilação/ Refinação de Metanol	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	

		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	

		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

35_Rotura da Linha de fundo da coluna de refinação 43-C-002

Pressure vessel

CapWatt_Mangualde_HyMeOH\120s

Tab	Group	Field	Value	Units
Material	Material	Material	FUSEL ÓLEO	
		Specify volume inventory?	No	
		Mass inventory	6,66667	kg
		Volume inventory	0,00950706	m3
		Material to track	FUSEL ÓLEO	
	Phase	Specified condition	Pressure/temperature	
		Temperature	45	degC
		Pressure (gauge)	5	bar
		Fluid state	Liquid	
		Liquid mole fraction	1	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	120	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	0,00950706	m3
		Tank vapour volume	0	m3
		Tank liquid volume	0,00950706	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack da U430 para a armazenagem de Fusel óleo	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	

		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

35_Rotura da Linha de fundo da coluna de refinação 43-C-002

Short pipe

CapWatt_Mangualde_HyMeOH\120s\35_Rotura da Linha de fundo da coluna de refinação 43-C-002

Tab	Group	Field	Value	Units
Scenario	Scenario	Scenario type	Line rupture	
	Pipe dimensions	Pipe internal diameter	254	mm
		Pipe length	120	m
	Hole	Orifice diameter		mm
	Release location	Elevation	0,1	m
		Tank head	0	m
	Flow control and isolation	Flow controller	Pump (liquid release)	
		Input option	Fixed flow rate	
		Fixed flow rate	0,05	kg/s
		Pump head		m
		Active isolation valve		
		Valve closing time		s
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Flammable only	
		Material to track	FUSEL ÓLEO	
	Phase	Phase to be released	Liquid	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m
	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m

		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack da U430 para a armazenagem de Fusel óleo	
Explosion parameters	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	

		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if	Yes	

		grounded		
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

36_Fuga da Linha de fundo da coluna de refinação 43-C-002

Pressure vessel

CapWatt_Mangualde_HyMeOH\120s

Tab	Group	Field	Value	Units
Material	Material	Material	FUSEL ÓLEO	
		Specify volume inventory?	No	
		Mass inventory	6,66667	kg
		Volume inventory	0,00950706	m3
		Material to track	FUSEL ÓLEO	
	Phase	Specified condition	Pressure/temperature	
		Temperature	45	degC
		Pressure (gauge)	5	bar
		Fluid state	Liquid	
		Liquid mole fraction	1	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	120	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	0,00950706	m3
		Tank vapour volume	0	m3
		Tank liquid volume	0,00950706	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack da U430 para a armazenagem de Fusel óleo	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	

		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

36_Fuga da Linha de fundo da coluna de refinação 43-C-002

Leak

CapWatt_Mangualde_HyMeOH\120s\36_Fuga da Linha de fundo da coluna de refinação 43-C-002

Tab	Group	Field	Value	Units
Scenario	Hole	Orifice diameter	2,54	mm
		Use specified discharge coefficient?	Yes	
		Discharge coefficient	0,62	fraction
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Flammable only	
		Material to track	FUSEL ÓLEO	
	Phase	Phase to be released	Liquid	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - continuous	Do not force correlation	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack da U430 para a armazenagem de Fusel óleo	
Explosion parameters	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	

		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	

		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

37_Rotura da Linha de fundo da Purga 42-V-004

Pressure vessel

CapWatt_Mangualde_HyMeOH\120s

Tab	Group	Field	Value	Units
Material	Material	Material	METHANOL	
		Specify volume inventory?	No	
		Mass inventory	7,06667	kg
		Volume inventory	0,952713	m3
		Material to track	METHANOL	
	Phase	Specified condition	Pressure/temperature	
		Temperature	170	degC
		Pressure (gauge)	7	bar
		Fluid state	Vapour	
		Liquid mole fraction	0	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	150	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	0,952713	m3
		Tank vapour volume	0,952713	m3
		Tank liquid volume	0	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Área de Síntese de Metanol	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	

		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

37_Rotura da Linha de fundo da Purga 42-V-004

Short pipe

CapWatt_Mangualde_HyMeOH\120s\37_Rotura da Linha de fundo da Purga 42-V-004

Tab	Group	Field	Value	Units
Scenario	Scenario	Scenario type	Line rupture	
	Pipe dimensions	Pipe internal diameter	25,4	mm
		Pipe length	150	m
	Hole	Orifice diameter		mm
	Release location	Elevation	0,1	m
		Tank head	0	m
	Flow control and isolation	Flow controller	None	
		Input option	Not applicable	
		Fixed flow rate	0,06	kg/s
		Pump head		m
		Active isolation valve		
		Valve closing time		s
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Toxic and flammable	
		Material to track	METHANOL	
	Phase	Phase to be released	Vapour	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m
	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return	0	/m

		valves		
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Área de Síntese de Metanol	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction

Explosion parameters	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
	Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	

		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

38_Fuga da Linha de fundo de Purga 42-V-004

Pressure vessel

CapWatt_Mangualde_HyMeOH\120s

Tab	Group	Field	Value	Units
Material	Material	Material	METHANOL	
		Specify volume inventory?	No	
		Mass inventory	7,06667	kg
		Volume inventory	0,952713	m3
		Material to track	METHANOL	
	Phase	Specified condition	Pressure/temperature	
		Temperature	170	degC
		Pressure (gauge)	7	bar
		Fluid state	Vapour	
		Liquid mole fraction	0	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	150	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	0,952713	m3
		Tank vapour volume	0,952713	m3
		Tank liquid volume	0	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Área de Síntese de Metanol	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	

		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

38_Fuga da Linha de fundo de Purga 42-V-004

Leak

CapWatt_Mangualde_HyMeOH\120s\38_Fuga da Linha de fundo de Purga 42-V-004

Tab	Group	Field	Value	Units
Scenario	Hole	Orifice diameter	2,54	mm
		Use specified discharge coefficient?	Yes	
		Discharge coefficient	0,62	fraction
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Toxic and flammable	
		Material to track	METHANOL	
	Phase	Phase to be released	Vapour	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - continuous	Do not force correlation	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	

		Type of pool substrate and bunds	Área de Síntese de Metanol	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	

		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	

		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

39_Rotura linha de envio de Metanol bruto à Destilação de Metanol via P-4001A

Pressure vessel

CapWatt_Mangualde_HyMeOH\120s

Tab	Group	Field	Value	Units
Material	Material	Material	METANOL BRUTO	
		Specify volume inventory?	No	
		Mass inventory	2952	kg
		Volume inventory	1003,3	m3
		Material to track	METANOL BRUTO	
	Phase	Specified condition	Pressure/temperature	
		Temperature	25	degC
		Pressure (gauge)	6	bar
		Fluid state	Vapour	
		Liquid mole fraction	0	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	75	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	1003,3	m3
		Tank vapour volume	1003,3	m3
		Tank liquid volume	0	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack da armazenagem de Metanol Bruto para U-430	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	

		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m ³
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m ²
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

39_Rotura linha de envio de Metanol bruto à Destilação de Metanol via P-4001A

Short pipe

CapWatt_Mangualde_HyMeOH\120s\39_Rotura linha de envio de Metanol bruto à Destilação de Metanol via P-4001A

Tab	Group	Field	Value	Units
Scenario	Scenario	Scenario type	Line rupture	
	Pipe dimensions	Pipe internal diameter	50,8	mm
		Pipe length	75	m
	Hole	Orifice diameter		mm
	Release location	Elevation	0,1	m
		Tank head	0	m
	Flow control and isolation	Flow controller	None	
		Input option	Not applicable	
		Fixed flow rate	24,6	kg/s
		Pump head		m
		Active isolation valve		
		Valve closing time		s
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Toxic and flammable	
		Material to track	METANOL BRUTO	
	Phase	Phase to be released	Vapour	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m
	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return	0	/m

Audit Number: 11245

Date: 10/10/2025 Time: 11:19

Page 221 of 289

		valves		
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack da armazenagem de Metanol Bruto para U-430	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction

Explosion parameters	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
	Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	

		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

40_Fuga 10% do diâmetro da linha de envio de Metanol bruto à Destilação de Metanol via P-4001A

Pressure vessel

CapWatt_Mangualde_HyMeOH\120s

Tab	Group	Field	Value	Units
Material	Material	Material	METANOL BRUTO	
		Specify volume inventory?	No	
		Mass inventory	2952	kg
		Volume inventory	1003,3	m3
		Material to track	METANOL BRUTO	
	Phase	Specified condition	Pressure/temperature	
		Temperature	25	degC
		Pressure (gauge)	6	bar
		Fluid state	Vapour	
		Liquid mole fraction	0	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	75	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	1003,3	m3
		Tank vapour volume	1003,3	m3
		Tank liquid volume	0	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack da armazenagem de Metanol Bruto para U-430	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	

		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

40_Fuga 10% do diâmetro da linha de envio de Metanol bruto à Destilação de Metanol via P-4001A

Leak

CapWatt_Mangualde_HyMeOH\120s\40_Fuga 10% do diâmetro da linha de envio de Metanol bruto à Destilação de Metanol via P-4001A

Tab	Group	Field	Value	Units
Scenario	Hole	Orifice diameter	5,08	mm
		Use specified discharge coefficient?	Yes	
		Discharge coefficient	0,62	fraction
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Toxic and flammable	
		Material to track	METANOL BRUTO	
	Phase	Phase to be released	Vapour	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - continuous	Do not force correlation	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and	Terrain and bund	Type of terrain for	Land	

Audit Number: 11245

Date: 10/10/2025 Time: 11:19

Page 231 of 289

terrain	definition	dispersion		
		Type of pool substrate and bunds	Piperack da armazenagem de Metanol Bruto para U-430	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction

Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	

		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

41_Rotura da linha de envio de fuel gas para a Cogeração

Pressure vessel

CapWatt_Mangualde_HyMeOH\120s

Tab	Group	Field	Value	Units
Material	Material	Material	FUELGAS	
		Specify volume inventory?	No	
		Mass inventory	19	kg
		Volume inventory	4,86919	m3
		Material to track	FUELGAS	
	Phase	Specified condition	Pressure/temperature	
		Temperature	38	degC
		Pressure (gauge)	2,5	bar
		Fluid state	Vapour	
		Liquid mole fraction	0	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	230	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	4,86919	m3
		Tank vapour volume	4,86919	m3
		Tank liquid volume	0	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack da U430 para a Cogeração	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	

		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

41_Rotura da linha de envio de fuel gas para a Cogeração

Short pipe

CapWatt_Mangualde_HyMeOH\120s\41_Rotura da linha de envio de fuel gas para a Cogeração

Tab	Group	Field	Value	Units
Scenario	Scenario	Scenario type	Line rupture	
	Pipe dimensions	Pipe internal diameter	50,8	mm
		Pipe length	230	m
	Hole	Orifice diameter		mm
	Release location	Elevation	0,1	m
		Tank head	0	m
	Flow control and isolation	Flow controller	None	
		Input option	Not applicable	
		Fixed flow rate	0,16	kg/s
		Pump head		m
		Active isolation valve		
		Valve closing time		s
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Toxic and flammable	
		Material to track	FUELGAS	
	Phase	Phase to be released	Vapour	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m
	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return	0	/m

		valves		
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack da U430 para a Cogeração	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction

Explosion parameters	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
	Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	

		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

42_Fuga 10% do diâmetro da linha de envio de fuel gas para a Cogeração

Pressure vessel

CapWatt_Mangualde_HyMeOH\120s

Tab	Group	Field	Value	Units
Material	Material	Material	FUELGAS	
		Specify volume inventory?	No	
		Mass inventory	19	kg
		Volume inventory	4,86919	m3
		Material to track	FUELGAS	
	Phase	Specified condition	Pressure/temperature	
		Temperature	38	degC
		Pressure (gauge)	2,5	bar
		Fluid state	Vapour	
		Liquid mole fraction	0	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	230	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	4,86919	m3
		Tank vapour volume	4,86919	m3
		Tank liquid volume	0	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack da U430 para a Cogeração	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	

		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m ³
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m ²
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

42_Fuga 10% do diâmetro da linha de envio de fuel gas para a Cogeração

Leak

CapWatt_Mangualde_HyMeOH\120s\42_Fuga 10% do diâmetro da linha de envio de fuel gas para a Cogeração

Tab	Group	Field	Value	Units
Scenario	Hole	Orifice diameter	5,08	mm
		Use specified discharge coefficient?	Yes	
		Discharge coefficient	0,62	fraction
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Toxic and flammable	
		Material to track	FUELGAS	
	Phase	Phase to be released	Vapour	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - continuous	Do not force correlation	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	

		Type of pool substrate and bunds	Piperack da U430 para a Cogeração	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	

		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	

		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

51_Rotura de braço de carga de Cisternas com Metanol

Pressure vessel

CapWatt_Mangualde_HyMeOH\120s

Tab	Group	Field	Value	Units
Material	Material	Material	METHANOL	
		Specify volume inventory?	No	
		Mass inventory	2080	kg
		Volume inventory	2,70142	m3
		Material to track	METHANOL	
	Phase	Specified condition	Pressure/temperature	
		Temperature	45	degC
		Pressure (gauge)	0,3	bar
		Fluid state	Liquid	
		Liquid mole fraction	1	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length		m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	2,70142	m3
		Tank vapour volume	0	m3
		Tank liquid volume	2,70142	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Ilha de Carga de Cisternas	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	

		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

51_Rotura de braço de carga de Cisternas com Metanol

Short pipe

CapWatt_Mangualde_HyMeOH\120s\51_Rotura de braço de carga de Cisternas com Metanol

Tab	Group	Field	Value	Units
Scenario	Scenario	Scenario type	Line rupture	
	Pipe dimensions	Pipe internal diameter	76,2	mm
		Pipe length	5	m
	Hole	Orifice diameter		mm
	Release location	Elevation	0,1	m
		Tank head	0	m
	Flow control and isolation	Flow controller	Pump (liquid release)	
		Input option	Fixed flow rate	
		Fixed flow rate	17	kg/s
		Pump head		m
		Active isolation valve		
		Valve closing time		s
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Toxic and flammable	
		Material to track	METHANOL	
	Phase	Phase to be released	Liquid	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m
	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return	0	/m

		valves		
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Ilha de Carga de Cisternas	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction

Explosion parameters	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
	Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	

		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

52_Fuga 10% do diâmetro de braço de carga de Cisternas com Metanol

Pressure vessel

CapWatt_Mangualde_HyMeOH\120s

Tab	Group	Field	Value	Units
Material	Material	Material	METHANOL	
		Specify volume inventory?	No	
		Mass inventory	2080	kg
		Volume inventory	2,70142	m3
		Material to track	METHANOL	
	Phase	Specified condition	Pressure/temperature	
		Temperature	45	degC
		Pressure (gauge)	0,3	bar
		Fluid state	Liquid	
		Liquid mole fraction	1	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length		m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	2,70142	m3
		Tank vapour volume	0	m3
		Tank liquid volume	2,70142	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Ilha de Carga de Cisternas	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	

		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

52_Fuga 10% do diâmetro de braço de carga de Cisternas com Metanol

Leak

CapWatt_Mangualde_HyMeOH\120s\52_Fuga 10% do diâmetro de braço de carga de Cisternas com Metanol

Tab	Group	Field	Value	Units
Scenario	Hole	Orifice diameter	7,62	mm
		Use specified discharge coefficient?	Yes	
		Discharge coefficient	0,62	fraction
		Elevation	0,1	m
	Release location	Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Toxic and flammable	
		Material to track	METHANOL	
	Phase	Phase to be released	Liquid	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
		Droplet break-up mechanism	Droplet break-up mechanism - continuous	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
	Standardised toxic threshold concentrations and averaging times	User defined averaging time		s
		ERPG [1 hr]	No	
		IDLH [30 mins]	No	
Bund, building and terrain	Terrain and bund definition	STEL [15 mins]	No	
		Type of terrain for dispersion	Land	

Audit Number: 11245

Date: 10/10/2025 Time: 11:19

Page 269 of 289

		Type of pool substrate and bunds	Ilha de Carga de Cisternas	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	

		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	

		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

60_Rotura de braço de carga de Cisternas com Fusel óleo

Pressure vessel

CapWatt_Mangualde_HyMeOH\120s

Tab	Group	Field	Value	Units
Material	Material	Material	FUSEL ÓLEO	
		Specify volume inventory?	No	
		Mass inventory	1400	kg
		Volume inventory	1,99648	m3
		Material to track	FUSEL ÓLEO	
	Phase	Specified condition	Pressure/temperature	
		Temperature	45	degC
		Pressure (gauge)	5	bar
		Fluid state	Liquid	
		Liquid mole fraction	1	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length		m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	1,99648	m3
		Tank vapour volume	0	m3
		Tank liquid volume	1,99648	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Ilha de Carga de Cisternas	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	

		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

60_Rotura de braço de carga de Cisternas com Fusel óleo

Short pipe

CapWatt_Mangualde_HyMeOH\120s\60_Rotura de braço de carga de Cisternas com Fusel óleo

Tab	Group	Field	Value	Units
Scenario	Scenario	Scenario type	Line rupture	
	Pipe dimensions	Pipe internal diameter	76,2	mm
		Pipe length	5	m
	Hole	Orifice diameter		mm
	Release location	Elevation	0,1	m
		Tank head	0	m
	Flow control and isolation	Flow controller	Pump (liquid release)	
		Input option	Fixed flow rate	
		Fixed flow rate	11,67	kg/s
		Pump head		m
		Active isolation valve		
		Valve closing time		s
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Flammable only	
		Material to track	FUSEL ÓLEO	
	Phase	Phase to be released	Liquid	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m
	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m

		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Ilha de Carga de Cisternas	
Explosion parameters	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		

		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	

	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

61_Fuga 10% do diâmetro de braço de carga de Cisternas com Fusel óleo

Pressure vessel

CapWatt_Mangualde_HyMeOH\120s

Tab	Group	Field	Value	Units
Material	Material	Material	FUSEL ÓLEO	
		Specify volume inventory?	No	
		Mass inventory	1400	kg
		Volume inventory	1,99648	m3
		Material to track	FUSEL ÓLEO	
	Phase	Specified condition	Pressure/temperature	
		Temperature	45	degC
		Pressure (gauge)	5	bar
		Fluid state	Liquid	
		Liquid mole fraction	1	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length		m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	1,99648	m3
		Tank vapour volume	0	m3
		Tank liquid volume	1,99648	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Ilha de Carga de Cisternas	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	

		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

61_Fuga 10% do diâmetro de braço de carga de Cisternas com Fusel óleo

Leak

CapWatt_Mangualde_HyMeOH\120s\61_Fuga 10% do diâmetro de braço de carga de Cisternas com Fusel óleo

Tab	Group	Field	Value	Units
Scenario	Hole	Orifice diameter	7,62	mm
		Use specified discharge coefficient?	Yes	
		Discharge coefficient	0,62	fraction
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Flammable only	
		Material to track	FUSEL ÓLEO	
	Phase	Phase to be released	Liquid	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - continuous	Do not force correlation	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Ilha de Carga de Cisternas	
Explosion parameters	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	

		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	

		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s