

Input Report

Workspace: CapWatt_Mangualde_HyMeOH_Resposta_APA_2026

600s

Study

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026

Tab	Group	Field	Value
Context of calculations	Selection of context	Weathers to use for this study	Weather folder
		Parameters to use for this study	600s
Material	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land
		Type of pool substrate and bunds	Concrete, no bund
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected
		Building type (downwind building type)	Buildings\Building type

4_Rotura linha de alimentação de Oxigénio para o Gaseificador a partir da armazenagem

Pressure vessel

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s

Tab	Group	Field	Value	Units
Material	Material	Material	OXYGEN	
		Specify volume inventory?	No	
		Mass inventory	1020,67	kg
		Volume inventory	157,284	m3
		Material to track	OXYGEN	
	Phase	Specified condition	Pressure/temperature	
		Temperature	25	degC
		Pressure (gauge)	4	bar
		Fluid state	Vapour	
		Liquid mole fraction	0	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	400	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	157,284	m3
		Tank vapour volume	157,284	m3
		Tank liquid volume	0	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack de O2 para U-210	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Geometry	Geometry	East	0	m
		North	0	m

4_Rotura linha de alimentação de Oxigénio para o Gaseificador a partir da armazenagem

Short pipe

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s\4_Rotura linha de alimentação de Oxigénio para o Gaseificador a partir da armazenagem

Tab	Group	Field	Value	Units
Scenario	Scenario	Scenario type	Line rupture	
	Pipe dimensions	Pipe internal diameter	203,2	mm
		Pipe length	400	m
	Hole	Orifice diameter		mm
	Release location	Elevation	0,1	m
		Tank head	0	m
	Flow control and isolation	Flow controller	None	
		Input option	Not applicable	
		Fixed flow rate	1,7	kg/s
		Pump head		m
		Active isolation valve		
		Valve closing time		s
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Inert	
		Material to track	OXYGEN	
	Phase	Phase to be released	Vapour	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m
	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m

		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest	30000; 35000	ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest	User-defined	
		Specify user-defined averaging time	Yes	
		User defined averaging time	600	s
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack de O2 para U-210	

5_Fuga 10% do diâmetro da linha de alimentação de Oxigênio para o Gaseificador a partir da armazenagem

Pressure vessel

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s

Tab	Group	Field	Value	Units
Material	Material	Material	OXYGEN	
		Specify volume inventory?	No	
		Mass inventory	1020,67	kg
		Volume inventory	157,284	m3
		Material to track	OXYGEN	
	Phase	Specified condition	Pressure/temperature	
		Temperature	25	degC
		Pressure (gauge)	4	bar
		Fluid state	Vapour	
		Liquid mole fraction	0	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	400	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	157,284	m3
		Tank vapour volume	157,284	m3
		Tank liquid volume	0	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack de O2 para U-210	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Geometry	Geometry	East	0	m
		North	0	m

5_Fuga 10% do diâmetro da linha de alimentação de Oxigênio para o Gaseificador a partir da armazenagem

Leak

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s\5_Fuga 10% do diâmetro da linha de alimentação de Oxigênio para o Gaseificador a partir da armazenagem

Tab	Group	Field	Value	Units
Scenario	Hole	Orifice diameter	20,32	mm
		Use specified discharge coefficient?	Yes	
		Discharge coefficient	0,62	fraction
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Inert	
		Material to track	OXYGEN	
	Phase	Phase to be released	Vapour	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - continuous	Do not force correlation	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest	30000; 35000	ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest	User-defined	
		Specify user-defined averaging time	Yes	
		User defined averaging time	600	s
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack de O2 para U-210	

6_Rotura linha de alimentação de Oxigénio para o Gaseificador a partir da eletrólise

Pressure vessel

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s

Tab	Group	Field	Value	Units
Material	Material	Material	OXYGEN	
		Specify volume inventory?	No	
		Mass inventory	564	kg
		Volume inventory	13,866	m3
		Material to track	OXYGEN	
	Phase	Specified condition	Pressure/temperature	
		Temperature	25	degC
		Pressure (gauge)	30	bar
		Fluid state	Vapour	
		Liquid mole fraction	0	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	250	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	13,866	m3
		Tank vapour volume	13,866	m3
		Tank liquid volume	0	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack O2 da Eletrólise	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Geometry	Geometry	East	0	m
		North	0	m

6_Rotura linha de alimentação de Oxigénio para o Gaseificador a partir da eletrólise

Short pipe

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s\6_Rotura linha de alimentação de Oxigénio para o Gaseificador a partir da eletrólise

Tab	Group	Field	Value	Units
Scenario	Scenario	Scenario type	Line rupture	
	Pipe dimensions	Pipe internal diameter	101,6	mm
		Pipe length	250	m
	Hole	Orifice diameter		mm
	Release location	Elevation	0,1	m
		Tank head	0	m
	Flow control and isolation	Flow controller	None	
		Input option	Not applicable	
		Fixed flow rate	0,9	kg/s
		Pump head		m
		Active isolation valve		
		Valve closing time		s
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Inert	
		Material to track	OXYGEN	
	Phase	Phase to be released	Vapour	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m
	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m

		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest	30000; 35000	ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest	User-defined	
		Specify user-defined averaging time	Yes	
		User defined averaging time	600	s
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack O2 da Eletrólise	

7_Fuga 10% do diâmetro da linha de alimentação de Oxigênio para o Gaseificador a partir da eletrólise

Pressure vessel

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s

Tab	Group	Field	Value	Units
Material	Material	Material	OXYGEN	
		Specify volume inventory?	No	
		Mass inventory	564	kg
		Volume inventory	13,866	m3
		Material to track	OXYGEN	
	Phase	Specified condition	Pressure/temperature	
		Temperature	25	degC
		Pressure (gauge)	30	bar
		Fluid state	Vapour	
		Liquid mole fraction	0	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	250	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	13,866	m3
		Tank vapour volume	13,866	m3
		Tank liquid volume	0	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack O2 da Eletrólise	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Geometry	Geometry	East	0	m
		North	0	m

7_Fuga 10% do diâmetro da linha de alimentação de Oxigénio para o Gaseificador a partir da eletrólise

Leak

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s\7_Fuga 10% do diâmetro da linha de alimentação de Oxigénio para o Gaseificador a partir da eletrólise

Tab	Group	Field	Value	Units
Scenario	Hole	Orifice diameter	10,16	mm
		Use specified discharge coefficient?	Yes	
		Discharge coefficient	0,62	fraction
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Inert	
		Material to track	OXYGEN	
	Phase	Phase to be released	Vapour	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - continuous	Do not force correlation	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest	30000; 35000	ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest	User-defined	
		Specify user-defined averaging time	Yes	
		User defined averaging time	600	s
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack O2 da Eletrólise	

16_Rotura linha de saída do compressor de gás síntese 41-K-001 para a unidade de Síntese de Metanol

Pressure vessel

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s

Tab	Group	Field	Value	Units
Material	Material	Material	GÁS SÍNTESE	
		Specify volume inventory?	No	
		Mass inventory	6973	kg
		Volume inventory	228,774	m3
		Material to track	GÁS SÍNTESE	
	Phase	Specified condition	Pressure/temperature	
		Temperature	92	degC
		Pressure (gauge)	73	bar
		Fluid state	Vapour	
		Liquid mole fraction	0	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	35	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	228,774	m3
		Tank vapour volume	228,774	m3
		Tank liquid volume	0	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Área de Compressão de Gás Síntese	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	

		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

16_Rotura linha de saída do compressor de gás síntese 41-K-001 para a unidade de Síntese de Metanol

Short pipe

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s\16_Rotura linha de saída do compressor de gás síntese 41-K-001 para a unidade de Síntese de Metanol

Tab	Group	Field	Value	Units
Scenario	Scenario	Scenario type	Line rupture	
	Pipe dimensions	Pipe internal diameter	152,4	mm
		Pipe length	35	m
	Hole	Orifice diameter		mm
	Release location	Elevation	0,1	m
		Tank head	0	m
	Flow control and isolation	Flow controller	None	
		Input option	Not applicable	
		Fixed flow rate	12	kg/s
		Pump head		m
		Active isolation valve		
		Valve closing time		s
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Toxic and flammable	
		Material to track	GÁS SÍNTESE	
	Phase	Phase to be released	Vapour	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m
	Frequencies of valves	Frequency of excess flow valves	0	/m

		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Área de Compressão de Gás Síntese	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for	0	fraction

exposure time calculations				
Explosion parameters	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
	Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s

	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

17_Fuga 10% do diâmetro da linha de saída do compressor de gás síntese 41-K-001 para a unidade de Síntese de Metanol

Pressure vessel

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s

Tab	Group	Field	Value	Units
Material	Material	Material	GÁS SÍNTESE	
		Specify volume inventory?	No	
		Mass inventory	6973	kg
		Volume inventory	228,774	m3
		Material to track	GÁS SÍNTESE	
	Phase	Specified condition	Pressure/temperature	
		Temperature	92	degC
		Pressure (gauge)	73	bar
		Fluid state	Vapour	
		Liquid mole fraction	0	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	35	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in	0	/m

		pipe		
	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	228,774	m3
		Tank vapour volume	228,774	m3
		Tank liquid volume	0	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	

		User defined averaging time	s	
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Área de Compressão de Gás Síntese	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition	No ignition location	

		location		
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	

		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

17_Fuga 10% do diâmetro da linha de saída do compressor de gás síntese 41-K-001 para a unidade de Síntese de Metanol

Leak

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s\17_Fuga 10% do diâmetro da linha de saída do compressor de gás síntese 41-K-001 para a unidade de Síntese de Metanol

Tab	Group	Field	Value	Units
Scenario	Hole	Orifice diameter	15,24	mm
		Use specified discharge coefficient?	Yes	
		Discharge coefficient	0,62	fraction
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Toxic and flammable	
		Material to track	GÁS SÍNSESE	
	Phase	Phase to be released	Vapour	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - continuous	Do not force correlation	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	

Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Área de Compressão de Gás Síntese	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of		fraction

		confined source		
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction

Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

20_Rotura linha de alimentação de Hidrogénio para a unidade U-410 a partir da eletrólise

Pressure vessel

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s

Tab	Group	Field	Value	Units
Material	Material	Material	HYDROGEN	
		Specify volume inventory?	No	
		Mass inventory	72,1667	kg
		Volume inventory	27,5068	m3
		Material to track	HYDROGEN	
	Phase	Specified condition	Pressure/temperature	
		Temperature	25	degC
		Pressure (gauge)	32	bar
		Fluid state	Vapour	
		Liquid mole fraction	0	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	150	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	27,5068	m3
		Tank vapour volume	27,5068	m3
		Tank liquid volume	0	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piprack H2 da Eletrólise	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	

		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

20_Rotura linha de alimentação de Hidrogénio para a unidade U-410 a partir da eletrólise

Short pipe

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s\20_Rotura linha de alimentação de Hidrogénio para a unidade U-410 a partir da eletrólise

Tab	Group	Field	Value	Units
Scenario	Scenario	Scenario type	Line rupture	
	Pipe dimensions	Pipe internal diameter	50,8	mm
		Pipe length	150	m
	Hole	Orifice diameter		mm
	Release location	Elevation	0,1	m
		Tank head	0	m
	Flow control and isolation	Flow controller	None	
		Input option	Not applicable	
		Fixed flow rate	0,1	kg/s
		Pump head		m
		Active isolation valve		
		Valve closing time		s
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Flammable only	
		Material to track	HYDROGEN	
	Phase	Phase to be released	Vapour	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m
	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m

		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack H2 da Eletrólise	
Explosion parameters	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		

		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	

	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

21_Fuga 10% do diâmetro da linha de alimentação de Hidrogénio para a unidade U410 a partir da eletrólise

Pressure vessel

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s

Tab	Group	Field	Value	Units
Material	Material	Material	HYDROGEN	
		Specify volume inventory?	No	
		Mass inventory	72,1667	kg
		Volume inventory	27,5068	m3
		Material to track	HYDROGEN	
	Phase	Specified condition	Pressure/temperature	
		Temperature	25	degC
		Pressure (gauge)	32	bar
		Fluid state	Vapour	
		Liquid mole fraction	0	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	150	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	27,5068	m3
		Tank vapour volume	27,5068	m3
		Tank liquid volume	0	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperrack H2 da Eletrólise	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	

		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

21_Fuga 10% do diâmetro da linha de alimentação de Hidrogénio para a unidade U410 a partir da eletrólise Leak

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s\21_Fuga 10% do diâmetro da linha de alimentação de Hidrogénio para a unidade U410 a partir da eletrólise

Tab	Group	Field	Value	Units
Scenario	Hole	Orifice diameter	5,08	mm
		Use specified discharge coefficient?	Yes	
		Discharge coefficient	0,62	fraction
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Flammable only	
		Material to track	HYDROGEN	
	Phase	Phase to be released	Vapour	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - continuous	Do not force correlation	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack H2 da Eletrólise	
Explosion parameters	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	

		Location of late ignition	m	
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	

		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

25_Rotura da linha de fundo do Flash Drum 42-V-003 da síntese de metanol

Pressure vessel

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s

Tab	Group	Field	Value	Units
Material	Material	Material	METANOL BRUTO	
		Specify volume inventory?	No	
		Mass inventory	1896	kg
		Volume inventory	810,977	m3
		Material to track	METANOL BRUTO	
	Phase	Specified condition	Pressure/temperature	
		Temperature	48	degC
		Pressure (gauge)	5	bar
		Fluid state	Vapour	
		Liquid mole fraction	0	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	7	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	810,977	m3
		Tank vapour volume	810,977	m3
		Tank liquid volume	0	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Área de Síntese de Metanol	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	

		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

25_Rotura da linha de saída do Flash Drum 42-V-003 da síntese de metanol

Short pipe

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s\25_Rotura da linha de fundo do Flash Drum 42-V-003 da síntese de metanol

Tab	Group	Field	Value	Units
Scenario	Scenario	Scenario type	Line rupture	
	Pipe dimensions	Pipe internal diameter	76,2	mm
		Pipe length	7	m
	Hole	Orifice diameter		mm
	Release location	Elevation	0,1	m
		Tank head	0	m
	Flow control and isolation	Flow controller	None	
		Input option	Not applicable	
		Fixed flow rate	3	kg/s
		Pump head		m
		Active isolation valve		
		Valve closing time		s
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Toxic and flammable	
		Material to track	METANOL BRUTO	
	Phase	Phase to be released	Vapour	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m
	Frequencies of valves	Frequency of excess flow valves	0	/m

		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Área de Síntese de Metanol	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for	0	fraction

exposure time calculations				
Explosion parameters	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
	Multi-Energy	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s

	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

26_Fuga da linha de fundo do Flash Drum 42-V-003 da síntese de metanol

Pressure vessel

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s

Tab	Group	Field	Value	Units
Material	Material	Material	METANOL BRUTO	
		Specify volume inventory?	No	
		Mass inventory	1896	kg
		Volume inventory	810,977	m3
		Material to track	METANOL BRUTO	
	Phase	Specified condition	Pressure/temperature	
		Temperature	48	degC
		Pressure (gauge)	5	bar
		Fluid state	Vapour	
		Liquid mole fraction	0	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	7	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	810,977	m3
		Tank vapour volume	810,977	m3
		Tank liquid volume	0	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Área de Síntese de Metanol	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	

		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

26_Fuga da linha de saída do Flash Drum 42-V-003 da síntese de metanol

Leak

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s\26_Fuga da linha de fundo do Flash Drum 42-V-003 da síntese de metanol

Tab	Group	Field	Value	Units
Scenario	Hole	Orifice diameter	7,62	mm
		Use specified discharge coefficient?	Yes	
		Discharge coefficient	0,62	fraction
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Toxic and flammable	
		Material to track	METANOL BRUTO	
	Phase	Phase to be released	Vapour	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - continuous	Do not force correlation	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and	Terrain and bund	Type of terrain for	Land	

Audit Number: 11630

Date: 22/04/2026 Time: 15:00

Page 73 of 186

terrain	definition	dispersion		
		Type of pool substrate and bunds	Área de Síntese de Metanol	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction

Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	

		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

30_Rotura da Linha de topo da coluna de destilação 43-C-001

Pressure vessel

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s

Tab	Group	Field	Value	Units
Material	Material	Material	METANOL BRUTO	
		Specify volume inventory?	No	
		Mass inventory	1928	kg
		Volume inventory	3375,28	m3
		Material to track	METANOL BRUTO	
	Phase	Specified condition	Pressure/temperature	
		Temperature	79	degC
		Pressure (gauge)	0,6	bar
		Fluid state	Vapour	
		Liquid mole fraction	0	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	5	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	3375,28	m3
		Tank vapour volume	3375,28	m3
		Tank liquid volume	0	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Área de Destilação/ Refinação de Metanol	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	

		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

30_Rotura da Linha de topo da coluna de destilação 43-C-001

Short pipe

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s\30_Rotura da Linha de topo da coluna de destilação 43-C-001

Tab	Group	Field	Value	Units
Scenario	Scenario	Scenario type	Line rupture	
	Pipe dimensions	Pipe internal diameter	254	mm
		Pipe length	5	m
	Hole	Orifice diameter		mm
	Release location	Elevation	0,1	m
		Tank head	0	m
	Flow control and isolation	Flow controller	None	
		Input option	Not applicable	
		Fixed flow rate	3	kg/s
		Pump head		m
		Active isolation valve		
		Valve closing time		s
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Toxic and flammable	
		Material to track	METANOL BRUTO	
	Phase	Phase to be released	Vapour	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m
	Frequencies of valves	Frequency of excess flow valves	0	/m

		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Área de Destilação/ Refinação de Metanol	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for	0	fraction

exposure time calculations				
Explosion parameters	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
	Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s

	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

31_Fuga da Linha de topo da coluna de destilação 43-C-001

Pressure vessel

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s

Tab	Group	Field	Value	Units
Material	Material	Material	METANOL BRUTO	
		Specify volume inventory?	No	
		Mass inventory	1928	kg
		Volume inventory	3375,28	m3
		Material to track	METANOL BRUTO	
	Phase	Specified condition	Pressure/temperature	
		Temperature	79	degC
		Pressure (gauge)	0,6	bar
		Fluid state	Vapour	
		Liquid mole fraction	0	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	5	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	3375,28	m3
		Tank vapour volume	3375,28	m3
		Tank liquid volume	0	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Área de Destilação/ Refinação de Metanol	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	

		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

31_Fuga da Linha de topo da coluna de destilação 43-C-001

Leak

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s\31_Fuga da Linha de topo da coluna de destilação 43-C-001

Tab	Group	Field	Value	Units
Scenario	Hole	Orifice diameter	25,4	mm
		Use specified discharge coefficient?	Yes	
		Discharge coefficient	0,62	fraction
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Toxic and flammable	
		Material to track	METANOL BRUTO	
	Phase	Phase to be released	Vapour	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - continuous	Do not force correlation	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	

Audit Number: 11630

Date: 22/04/2026 Time: 15:00

Page 92 of 186

		Type of pool substrate and bunds	Área de Destilação/ Refinação de Metanol	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	

		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	

		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

35_Rotura da Linha de fundo da coluna de refinação 43-C-002

Pressure vessel

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s

Tab	Group	Field	Value	Units
Material	Material	Material	FUSEL ÓLEO	
		Specify volume inventory?	No	
		Mass inventory	33	kg
		Volume inventory	0,04706	m3
		Material to track	FUSEL ÓLEO	
	Phase	Specified condition	Pressure/temperature	
		Temperature	45	degC
		Pressure (gauge)	5	bar
		Fluid state	Liquid	
		Liquid mole fraction	1	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	120	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	0,04706	m3
		Tank vapour volume	0	m3
		Tank liquid volume	0,04706	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack da U430 para a armazenagem de Fusel óleo	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	

		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

35_Rotura da Linha de fundo da coluna de refinação 43-C-002

Short pipe

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s\35_Rotura da Linha de fundo da coluna de refinação 43-C-002

Tab	Group	Field	Value	Units
Scenario	Scenario	Scenario type	Line rupture	
	Pipe dimensions	Pipe internal diameter	254	mm
		Pipe length	120	m
	Hole	Orifice diameter		mm
	Release location	Elevation	0,1	m
		Tank head	0	m
	Flow control and isolation	Flow controller	Pump (liquid release)	
		Input option	Fixed flow rate	
		Fixed flow rate	0,05	kg/s
		Pump head		m
		Active isolation valve		
		Valve closing time		s
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Flammable only	
		Material to track	FUSEL ÓLEO	
	Phase	Phase to be released	Liquid	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m
	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m

		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack da U430 para a armazenagem de Fusel óleo	
Explosion parameters	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	

		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
	Radiation levels	Calculate lethality	No	
		Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
	Parameters	Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
		Mass modification factor	3	
		Fireball maximum exposure duration	20	s
Jet fire	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
	Radiation levels	Calculate lethality	No	
		Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
	Parameters	Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
		Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if	Yes	

		grounded		
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

36_Fuga da Linha de fundo da coluna de refinação 43-C-002

Pressure vessel

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s

Tab	Group	Field	Value	Units
Material	Material	Material	FUSEL ÓLEO	
		Specify volume inventory?	No	
		Mass inventory	33	kg
		Volume inventory	0,04706	m3
		Material to track	FUSEL ÓLEO	
	Phase	Specified condition	Pressure/temperature	
		Temperature	45	degC
		Pressure (gauge)	5	bar
		Fluid state	Liquid	
		Liquid mole fraction	1	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	120	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	0,04706	m3
		Tank vapour volume	0	m3
		Tank liquid volume	0,04706	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack da U430 para a armazenagem de Fusel óleo	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	

		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

36_Fuga da Linha de fundo da coluna de refinação 43-C-002

Leak

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s\36_Fuga da Linha de fundo da coluna de refinação 43-C-002

Tab	Group	Field	Value	Units
Scenario	Hole	Orifice diameter	2,54	mm
		Use specified discharge coefficient?	Yes	
		Discharge coefficient	0,62	fraction
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Flammable only	
		Material to track	FUSEL ÓLEO	
	Phase	Phase to be released	Liquid	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - continuous	Do not force correlation	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack da U430 para a armazenagem de Fusel óleo	
Explosion parameters	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	

		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	

		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

39_Rotura linha de envio de Metanol bruto à Destilação de Metanol via P-44003A

Pressure vessel

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s

Tab	Group	Field	Value	Units
Material	Material	Material	METANOL BRUTO	
		Specify volume inventory?	No	
		Mass inventory	14760	kg
		Volume inventory	5016,52	m3
		Material to track	METANOL BRUTO	
	Phase	Specified condition	Pressure/temperature	
		Temperature	25	degC
		Pressure (gauge)	6	bar
		Fluid state	Vapour	
		Liquid mole fraction	0	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	75	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	5016,52	m3
		Tank vapour volume	5016,52	m3
		Tank liquid volume	0	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack da armazenagem de Metanol Bruto para U-430	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	

		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

39_Rotura linha de envio de Metanol bruto à Destilação de Metanol via P-44003A

Short pipe

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s\39_Rotura linha de envio de Metanol bruto à Destilação de Metanol via P-44003A

Tab	Group	Field	Value	Units
Scenario	Scenario	Scenario type	Line rupture	
	Pipe dimensions	Pipe internal diameter	50,8	mm
		Pipe length	75	m
	Hole	Orifice diameter		mm
	Release location	Elevation	0,1	m
		Tank head	0	m
	Flow control and isolation	Flow controller	None	
		Input option	Not applicable	
		Fixed flow rate	24,6	kg/s
		Pump head		m
		Active isolation valve		
		Valve closing time		s
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Toxic and flammable	
		Material to track	METANOL BRUTO	
	Phase	Phase to be released	Vapour	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m
	Frequencies of valves	Frequency of excess flow valves	0	/m

		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack da armazenagem de Metanol Bruto para U-430	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for	0	fraction

exposure time calculations				
Explosion parameters	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
	Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s

	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

40_Fuga 10% do diâmetro da linha de envio de Metanol bruto à Destilação de Metanol via P-44003A

Pressure vessel

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s

Tab	Group	Field	Value	Units
Material	Material	Material	METANOL BRUTO	
		Specify volume inventory?	No	
		Mass inventory	14760	kg
		Volume inventory	5016,52	m3
		Material to track	METANOL BRUTO	
	Phase	Specified condition	Pressure/temperature	
		Temperature	25	degC
		Pressure (gauge)	6	bar
		Fluid state	Vapour	
		Liquid mole fraction	0	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	75	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	5016,52	m3
		Tank vapour volume	5016,52	m3
		Tank liquid volume	0	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack da armazenagem de Metanol Bruto para U-430	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	

		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

40_Fuga 10% do diâmetro da linha de envio de Metanol bruto à Destilação de Metanol via P-44003A

Leak

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s\40_Fuga 10% do diâmetro da linha de envio de Metanol bruto à Destilação de Metanol via P-44003A

Tab	Group	Field	Value	Units
Scenario	Hole	Orifice diameter	5,08	mm
		Use specified discharge coefficient?	Yes	
		Discharge coefficient	0,62	fraction
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Toxic and flammable	
		Material to track	METANOL BRUTO	
	Phase	Phase to be released	Vapour	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - continuous	Do not force correlation	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and	Terrain and bund	Type of terrain for	Land	

Audit Number: 11630

Date: 22/04/2026 Time: 15:00

Page 128 of 186

terrain	definition	dispersion		
		Type of pool substrate and bunds	Piperack da armazenagem de Metanol Bruto para U-430	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction

Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	

		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

49_Rotura da linha de envio de Metanol para as Ilhas de Carga de Cisternas

Pressure vessel

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s

Tab	Group	Field	Value	Units
Material	Material	Material	METHANOL	
		Specify volume inventory?	No	
		Mass inventory	10400	kg
		Volume inventory	13,1711	m3
		Material to track	METHANOL	
	Phase	Specified condition	Pressure/temperature	
		Temperature	25	degC
		Pressure (gauge)	8	bar
		Fluid state	Liquid	
		Liquid mole fraction	1	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	110	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	13,1711	m3
		Tank vapour volume	0	m3
		Tank liquid volume	13,1711	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack da armazenagem de Metanol para as Ilhas de Carga de Cisternas	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition	No ignition location	

		location		
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	

		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

49_Rotura da linha de envio de Metanol para as Ilhas de Carga de Cisternas

Short pipe

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s\49_Rotura da linha de envio de Metanol para as Ilhas de Carga de Cisternas

Tab	Group	Field	Value	Units
Scenario	Scenario	Scenario type	Line rupture	
	Pipe dimensions	Pipe internal diameter	76,2	mm
		Pipe length	110	m
	Hole	Orifice diameter		mm
	Release location	Elevation	0,1	m
		Tank head	0	m
	Flow control and isolation	Flow controller	Pump (liquid release)	
		Input option	Fixed flow rate	
		Fixed flow rate	17	kg/s
		Pump head		m
		Active isolation valve		
		Valve closing time		s
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Toxic and flammable	
		Material to track	METHANOL	
	Phase	Phase to be released	Liquid	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m
	Frequencies of valves	Frequency of excess flow valves	0	/m

		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack da armazenagem de Metanol para as Ilhas de Carga de Cisternas	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction

		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum	20	s

		exposure duration		
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum	20	s

exposure duration

50_Fuga 10% do diâmetro da linha de envio de Metanol para as Ilhas de Carga de Cisternas

Pressure vessel

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s

Tab	Group	Field	Value	Units
Material	Material	Material	METHANOL	
		Specify volume inventory?	No	
		Mass inventory	10400	kg
		Volume inventory	13,1711	m3
		Material to track	METHANOL	
	Phase	Specified condition	Pressure/temperature	
		Temperature	25	degC
		Pressure (gauge)	8	bar
		Fluid state	Liquid	
		Liquid mole fraction	1	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	110	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	13,1711	m3
		Tank vapour volume	0	m3
		Tank liquid volume	13,1711	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack da armazenagem de Metanol para as Ilhas de Carga de Cisternas	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition	No ignition location	

		location		
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	

		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

50_Fuga 10% do diâmetro da linha de envio de Metanol para as Ilhas de Carga de Cisternas

Leak

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s\50_Fuga 10% do diâmetro da linha de envio de Metanol para as Ilhas de Carga de Cisternas

Tab	Group	Field	Value	Units
Scenario	Hole	Orifice diameter	7,62	mm
		Use specified discharge coefficient?	Yes	
		Discharge coefficient	0,62	fraction
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Toxic and flammable	
		Material to track	METHANOL	
	Phase	Phase to be released	Liquid	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - continuous	Do not force correlation	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and	Terrain and bund	Type of terrain for	Land	

Audit Number: 11630

Date: 22/04/2026 Time: 15:00

Page 147 of 186

terrain	definition	dispersion		
		Type of pool substrate and bunds	Piperack da armazenagem de Metanol para as Ilhas de Carga de Cisternas	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of		fraction

		confined source		
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction

Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

56_Rotura da linha de envio de Metanol para as áreas de carga por ferrovia

Pressure vessel

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s

Tab	Group	Field	Value	Units
Material	Material	Material	METHANOL	
		Specify volume inventory?	No	
		Mass inventory	10398	kg
		Volume inventory	13,1685	m3
		Material to track	METHANOL	
	Phase	Specified condition	Pressure/temperature	
		Temperature	25	degC
		Pressure (gauge)	8	bar
		Fluid state	Liquid	
		Liquid mole fraction	1	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	50	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	13,1685	m3
		Tank vapour volume	0	m3
		Tank liquid volume	13,1685	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack da armazenagem de Metanol para a alimentação de carga ferroviária	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition	No ignition location	

		location		
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	

		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

56_Rotura da linha de envio de Metanol para as áreas de carga por ferrovia

Short pipe

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s\56_Rotura da linha de envio de Metanol para as áreas de carga por ferrovia

Tab	Group	Field	Value	Units
Scenario	Scenario	Scenario type	Line rupture	
	Pipe dimensions	Pipe internal diameter	203,2	mm
		Pipe length	50	m
	Hole	Orifice diameter		mm
	Release location	Elevation	0,1	m
		Tank head	0	m
	Flow control and isolation	Flow controller	Pump (liquid release)	
		Input option	Fixed flow rate	
		Fixed flow rate	17,33	kg/s
		Pump head		m
		Active isolation valve		
		Valve closing time		s
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Toxic and flammable	
		Material to track	METHANOL	
	Phase	Phase to be released	Liquid	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m
	Frequencies of valves	Frequency of excess flow valves	0	/m

		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack da armazenagem de Metanol para a alimentação de carga ferroviária	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction

		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum	20	s

		exposure duration		
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum	20	s

exposure duration

57_Fuga 10% do diâmetro da de envio de Metanol para as áreas de carga por ferrovia

Pressure vessel

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s

Tab	Group	Field	Value	Units
Material	Material	Material	METHANOL	
		Specify volume inventory?	No	
		Mass inventory	10398	kg
		Volume inventory	13,1685	m3
		Material to track	METHANOL	
	Phase	Specified condition	Pressure/temperature	
		Temperature	25	degC
		Pressure (gauge)	7	bar
		Fluid state	Liquid	
		Liquid mole fraction	1	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	50	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	13,1685	m3
		Tank vapour volume	0	m3
		Tank liquid volume	13,1685	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack da armazenagem de Metanol para a alimentação de carga ferroviária	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition	No ignition location	

		location		
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	

		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

57_Fuga 10% do diâmetro da de envio de Metanol para as áreas de carga por ferrovia

Leak

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s\57_Fuga 10% do diâmetro da de envio de Metanol para as áreas de carga por ferrovia

Tab	Group	Field	Value	Units
Scenario	Hole	Orifice diameter	20,32	mm
		Use specified discharge coefficient?	Yes	
		Discharge coefficient	0,62	fraction
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Toxic and flammable	
		Material to track	METHANOL	
	Phase	Phase to be released	Liquid	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - continuous	Do not force correlation	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
	Standardised toxic threshold concentrations and averaging times	ERPG [1 hr]	No	
		IDLH [30 mins]	No	
		STEL [15 mins]	No	
Bund, building and	Terrain and bund	Type of terrain for	Land	

Audit Number: 11630

Date: 22/04/2026 Time: 15:00

Page 166 of 186

terrain	definition	dispersion		
		Type of pool substrate and bunds	Piperack da armazenagem de Metanol para a alimentação de carga ferroviária	
Toxic parameters	Indoor toxic calculations	Specify the downwind building type	Unselected	
		Building type (downwind building type)	Buildings\Building type	
	Exposure time data	Set averaging time equal to exposure time	Use a fixed averaging time	
		Cut-off fraction of toxic load for exposure time calculation	0,05	fraction
		Cut-off concentration for exposure time calculations	0	fraction
	Toxic contours	Number of toxic levels	3	
		Dose levels [ppm^n.min]	130000; 1,3E+06; 1,3E+07	
		Probit levels	2; 3; 4	
		Lethality levels	0,001; 0,01; 0,1	fraction
Explosion parameters	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of		fraction

		confined source		
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction

Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

58_Rotura da linha de envio de Fusel óleo para a Ilha de Carga de Cisternas

Pressure vessel

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s

Tab	Group	Field	Value	Units
Material	Material	Material	FUSEL ÓLEO	
		Specify volume inventory?	No	
		Mass inventory	7002	kg
		Volume inventory	9,76636	m3
		Material to track	FUSEL ÓLEO	
	Phase	Specified condition	Pressure/temperature	
		Temperature	25	degC
		Pressure (gauge)	7	bar
		Fluid state	Liquid	
		Liquid mole fraction	1	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	25	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	9,76636	m3
		Tank vapour volume	0	m3
		Tank liquid volume	9,76636	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack da armazenagem de Fusel óleo para as Ilhas de Carga de Cisternas	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	

		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

58_Rotura da linha de envio de Fusel óleo para a Ilha de Carga de Cisternas

Short pipe

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s\58_Rotura da linha de envio de Fusel óleo para a Ilha de Carga de Cisternas

Tab	Group	Field	Value	Units
Scenario	Scenario	Scenario type	Line rupture	
	Pipe dimensions	Pipe internal diameter	101,6	mm
		Pipe length	25	m
	Hole	Orifice diameter		mm
	Release location	Elevation	0,1	m
		Tank head	0	m
	Flow control and isolation	Flow controller	Pump (liquid release)	
		Input option	Fixed flow rate	
		Fixed flow rate	11,67	kg/s
		Pump head		m
		Active isolation valve		
		Valve closing time		s
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Flammable only	
		Material to track	FUSEL ÓLEO	
	Phase	Phase to be released	Liquid	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m
	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m

		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack da armazenagem de Fusel óleo para as Ilhas de Carga de Cisternas	
Explosion parameters	Explosion method	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	

		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
	Radiation levels	Calculate lethality	No	
		Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
	Parameters	Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
		Mass modification factor	3	
		Fireball maximum exposure duration	20	s
Jet fire	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
	Radiation levels	Calculate lethality	No	
		Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
	Parameters	Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
		Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if	Yes	

		grounded		
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s

59_Fuga 10% do diâmetro da linha de envio de Fusel óleo para a Ilha de Carga de Cisternas

Pressure vessel

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s

Tab	Group	Field	Value	Units
Material	Material	Material	FUSEL ÓLEO	
		Specify volume inventory?	No	
		Mass inventory	7002	kg
		Volume inventory	9,76636	m3
		Material to track	FUSEL ÓLEO	
	Phase	Specified condition	Pressure/temperature	
		Temperature	25	degC
		Pressure (gauge)	7	bar
		Fluid state	Liquid	
		Liquid mole fraction	1	fraction
	Modelling of mixtures	Multi or pseudo-component modelling	PC modelling	
Scenario	Pipe dimensions	Pipe length	25	m
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - instantaneous	Use flashing correlation	
		Droplet break-up mechanism - continuous	Do not force correlation	
Short pipe	Pipe characteristics	Pipe roughness	0,045	mm
	Frequencies	Frequency of bends in pipe	0	/m
		Frequency of couplings in pipe	0	/m
		Frequency of junctions in pipe	0	/m

	Frequencies of valves	Frequency of excess flow valves	0	/m
		Frequency of non-return valves	0	/m
		Frequency of shut-off valves	0	/m
	Velocity head losses	Excess flow valve velocity head losses	0	
		Non-return valve velocity head losses	0	
		Shut-off valve velocity head losses	0	
Time varying releases	Modelling of time-varying leaks and line ruptures	Vacuum relief valve	Operating	
		Vacuum relief valve set point	0	bar
	Inventory data for time-varying releases	Tank volume	9,76636	m3
		Tank vapour volume	0	m3
		Tank liquid volume	9,76636	m3
		Tank liquid level	0	m
		Maximum vapour release height		m
		Minimum mass inventory	0,1	kg
		Maximum mass inventory	1E+09	kg
	Safety system modelling for time-varying releases	Safety system modelling (isolation and blowdown)	No	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging		s

		time		
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack da armazenagem de Fusel óleo para as Ilhas de Carga de Cisternas	
	Building definition	Release building		
		In-building release?	Outdoor	
		Building wake effect	Roof/lee	
		Wind or release angle from North	0	deg
		Handling of droplets	Trapped	
		Indoor mass modification factor	3	
Explosion parameters	Explosion method (Consequence calculations only)	Explosion method	Multi-Energy: User-defined	
	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	

		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Horizontal options	Use standard method	
		Correlation	Recommended	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	

	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s
Geometry	Geometry	East	0	m
		North	0	m

59_Fuga 10% do diâmetro da linha de envio de Fusel óleo para a Ilha de Carga de Cisternas

Leak

CapWatt_Mangualde_HyMeOH_Resposta_APA_2026\600s\59_Fuga 10% do diâmetro da linha de envio de Fusel óleo para a Ilha de Carga de Cisternas

Tab	Group	Field	Value	Units
Scenario	Hole	Orifice diameter	10,16	mm
		Use specified discharge coefficient?	Yes	
		Discharge coefficient	0,62	fraction
	Release location	Elevation	0,1	m
		Tank head	0	m
	Direction	Outdoor release direction	Horizontal	
		Outdoor release angle	0	deg
Material	Material	Material characteristics	Flammable only	
		Material to track	FUSEL ÓLEO	
	Phase	Phase to be released	Liquid	
Discharge parameters	Model settings	Atmospheric expansion method	DNV recommended	
		Phase change upstream of orifice?	Disallow liquid phase change only (metastable liquid)	
	Droplet break-up mechanism	Droplet break-up mechanism - continuous	Do not force correlation	
Dispersion	User-defined dispersion scope (N.B Based on the material to track)	Concentrations of interest		ppm
		Distances of interest		m
		Averaging time for concentrations and distances of interest		
		Specify user-defined averaging time	No	
		User defined averaging time		s
Bund, building and terrain	Terrain and bund definition	Type of terrain for dispersion	Land	
		Type of pool substrate and bunds	Piperack da armazenagem de Fusel óleo para as Ilhas de Carga de Cisternas	
Explosion parameters	Explosion method	Explosion method	Multi-Energy: User-defined	

	Ignition	Supply late ignition location	No ignition location	
		Location of late ignition		m
	Vapour liquid method	Use explosion mass modification factor	Yes	
		Explosion mass modification factor	3	
Multi-Energy	Multi-Energy: User-defined	Unconfined explosion strength	6	
		Unconfined explosion efficiency	100	%
	Confined explosion sources	Number of confined sources	0	
		Option for specifying size of confined sources	Use volumes	
		Strength of confined source		
		Volume of confined source		m3
		Volume fraction of confined source		fraction
Fireball	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Mass modification factor	3	
		Fireball maximum exposure duration	20	s
	Calculation method	Fireball model	Martinsen time varying	
		TNO model flame temperature	1726,85	degC
Jet fire	Jet fire method	Selection for jet fire method	Automatic selection / DNV recommended	
	Result types to calculate	Calculate probit	No	

		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Rate modification factor	3	
		Jet fire maximum exposure duration	20	s
	Cone model data	Correlation	Recommended	
		Horizontal options	Use standard method	
		Flame-shape adjustment if grounded	Yes	
	Surface emissive power	Calculation method for surface emissive power	Calculate SEP	
		Flame emissive power		kW/m2
		Emissivity fraction		fraction
Pool fire	Result types to calculate	Calculate probit	No	
		Calculate dose	No	
		Calculate lethality	No	
	Radiation levels	Number of input radiation levels	5	
		Intensity levels	37,5; 12,5; 7; 5; 3	kW/m2
		Probit levels	2,73; 3,72; 7,5	
		Dose levels	1,27E+06; 5,8E+06; 2,51E+07	
		Lethality levels	0,01; 0,1; 0,99	fraction
	Parameters	Radiative fraction for general fires	0,4	fraction
		Pool fire maximum exposure duration	20	s